

4 ALBERT EMBANKMENT
LONDON SE1 7SR
Telephone: +44 (0)20 7735 7611 Fax: +44 (0)20 7587 3210

MSC.1/Circ.1275/Corr.1
31 March 2017

**UNIFIED INTERPRETATION OF SOLAS CHAPTER II-2 ON THE NUMBER AND
ARRANGEMENT OF PORTABLE FIRE EXTINGUISHERS ON BOARD SHIPS**

Corrigendum

In the table of the annex, the words "No point if space is more than 20 m walking distance from an extinguisher at each deck level" are replaced with the words "Spaced not more than 20 m apart on both sides of the space at each deck level in each hold or compartment where vehicles are carried".
